

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO...1212

Dated...15.07.2026

It is certified that an inspection team headed by Praveen Kumar, JE (Name of Officers with designation) From Dighalbank. PHED inspected the **Milli Girls School, Talimabad, Tappu, Tarabari chowk, Dighalbank, Dist-Kishanganj, Bihar** (Name & Address of the School) on 11.07.2026 (date of inspection) and on the basis of Water Test Report Attached bearing no...1212...dated-15.07.26 of District Level Water Testing Laboratory under P.H.Division Kishanganj Certified that the **Milli Girls School** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till One Year.

Praveen Kumar
JE Dighalbank
11/07/26

15/07/26
Signature with seal:
Executive Engineer
P.H. Division Kishanganj

Designation :- Executive Engineer

Name & Address of the Office/Department :- Public Health Division, Kishanganj

To,

**Milli Girls School, Talimabad, Tappu,
Tarabari chowk, Dighalbank,
Dist-Kishanganj (Bihar)**
(Name & Address of the Institution)

Note :- The certificate is to be issued by authorized officer/PHED Lab/local bodies.

DISTRICT LEVEL WATER TESTING LABORATORY

UNDER

P.H. DIVISION KISHANGANJ

Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj

Sample Collected By: - School Staff

District - Kishanganj

Date of Sample Submitted in Lab :- 10.07.2026

Date of Reporting :- 12.07.2026

Sl.No	Block	Location	Turb.	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	Remarks
1	Dighalbank	Milli Girls School, Talimabad, Tappu, P.O- Tarabari chowk, Dighalbank, Pin- 855108 Dist- Kishanganj	1.04	6.95	0.48	63.36	61.2	15.84	5.77	11.82	156	101	
Desirable limit			1 NTU	6.5-8.5	1.0 mg/l	200 mg/l	200mg/l	75mg/l	30mg/l	250mg/l		500 mg/l	
permissible Limit *in absence of alternate source IS:10500 :2012			5 NTU	NR	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	µ mhos/cm	2000 mg/l	

NR- No Relaxation

Devi
12/07/26

SK
12/07/26

12/7/26

Lab.Assistant

P.H. Division Kishanganj

Chemist

P.H. Division Kishanganj

Assistant Engineer

P.H. Sub Division Kishanganj